

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Date:- 20-05-26

It is certified that an inspection team headed by PHC Baragan
(Name of officer with designation) from Dr. Sher mehammad M.O.C.
(Name of department / Office) inspected the **BRAINWING ACADEMY Village- Kuwar Bazar, Pargana- Kolasla, Tehsil- Pindra, District – Varanasi, U.P.** (Name and address of the school) on 18/05/2026 (date of inspection) and found that the facilities for the students and member of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the compus as per norms prescribed by the Central / State / U.T. Govt.

The above is valid for a period of 02 years

Singnature with Seal: 

Name : Dr. Sher mehammad

Designation : M.O.C. स्वास्थ्य विज्ञान अधिकारी

Name & Address of the office / Department : PHC

Baragan

To
BRAINWINGS ACADEMY
Village- Kuwar Bazar, Pargana- Kolasla,
Tehsil- Pindra, District – Varanasi, U.P.

B. Narayanaiah
Principal
BRAINWINGS ACADEMY
Kuar Varanasi

Manager
Manager
BRAINWINGS ACADEMY
Kuar Varanasi



ELITE TESTING LAB PVT. LTD.

Address: 102, Vajidpur, Ganeshpur, Near BHEL, Varanashi, U.P

+ 91 8317015201, 9031044020, 7033294020, 6287094020



AN ISO 17025:2017 & 9001:2015 CERTIFIED

NABL ACCREDITED LABORATORY

Test Report

Issued to: Brainwings Academy Vill+Post-Kuar Bazar, Dist.-Varanasi (U.P.) -221204		Date of report:	27.05.2026	
		Report number:	ETL23052026N002M	
		Sample Receipt date:	23.05.2026	
		Date of testing:	24.05.2026	
		Code number:	ETL00223052025M	
Sample Description:	Dirking Water			
Client Name:	Brainwings Academy			
Ref. Number:	Nil			
S. No.	Test	Test Method	Requirement (Requirement Ref. IS:10500:2012)(Desirable Limit/Permissible Limit)	Result
(A) Physical Parameter				
1.	Conductivity in Micro cimen/cm	IS 3025(Part 14):1984(RA 2013)	...	149
2.	Conductivity in, Max.	IS:3025(Part 4) 1987	5/15, Max.	<2
3.	Odour	IS 3025(Part 6):1983(RA 2012)	Agreeable	Agreeable
4.	pH Value	IS 3025(Part 11):1983(RA 2012)	6.5-8.5/No relaxation	6.8
5.	Total Dissolve Solids,mg/l	IS 3025(Part 16):1984(RA 2012)	500/2000, Max	79
6.	Turbidity, NTU	IS 3025(Part 10):1984(RA 2012)	1.0/5.0, Max.	ND
7.	Copper (as CU)	IS:3025(Part 42)	0.05/1.5	ND
(B) Chemical Parameter				
8.	Calcium (as Ca), mg/l	IS 3025(Part 40):1991(RA 2014)	75.0/200.0, Max.	17
9.	Chloride(as Cl), mg/l	IS 3025(Part 32):1988(RA 2014)	250/1000, Max.	24
10.	Manganese (as Mn)	APHA P3500MNB	0.1/0.03	ND
11.	Iron (as Fe), mg/l	IS 3025(Part 53):2003(RA 2014)	0.3/No relaxation	ND
12.	Magnesium (as Mg), mg/l	IS 3025(Part 46):1994(RA 2014)	30.0/100.0, Max.	29
13.	Nitrate (as NO ₃), mg/l	IS 3025(Part 34):1988(RA 2014)	45/No relaxation	1.36
14.	Sulphate (as SO ₄), mg/l	IS 3025(Part 24):1986(RA 2014)	200/400, Max.	17
15.	Total Hardness (as CaCO ₃), mg/l	IS 3025(Part 21):2009(RA 2014)	200/600, Max.	68
(C) Bacteriological Parameter				
16.	E. coli or thermo tolerant coliform bacteria	IS: 1622	Shall not be detectable	ND
17.	Total coliform bacteria	IS: 1622	Shall not be detectable	ND

ND = Not Detective

Remarks: - The sample conforms to the IS: 10500:2012 w.r.to above test results only.



Authorised Signatory

Raj Kumar

Head Office Plot No. 7802, Ring Road, Sukurhutu, Kanke, Ranchi (Jharkhand)

info@elitelaboratory.in | up@elitelaboratory.in | www.elitelaboratory.in

Bunorpathak
Principal
BRAINWINGS ACADEMY
Kuar Varanasi

Manager
BRAINWINGS ACADEMY
Kuar Varanasi